



PUBLIC WORKS DEPARTMENT

CITY OF PORTSMOUTH

680 Peverly Hill Road

Portsmouth N.H. 03801

(603) 427-1530 FAX (603) 427-1539

May 25, 2012

Stephanie Larson
NHDES
PO Box 95
29 Hazen Drive
Concord, NH 03301

Subject: Daily Maximum Fecal Violations
NPDES Permit No. NH0090000
Discharge No. 005A

Dear Ms. Larson:

This is the five-day follow up letter for a daily maximum fecal violation for the Pease Facility. The following conditions occurred:

Date of Sample: 5/22/12

Chlorine Residual before Dechlorination at the time of Sample: 7.9 mg/L

Chlorine Residual after Dechlorination at the time of Sample: 0.00 mg/L

Free Chlorine 0.6mg/L

Plant Flow at time of Sample: 0.71 MGD

Fecal Results: 30/100ml

Please call if you have any questions or need additional information.

Sincerely,

Peter Rice

Cc: Joy Hilton, USEPA
Paula Anania